

# Blue Jeans Cable

Network Cable Test Report -- for more details, protocols, etc. see  
[www.bluejeanscable.com/networkcablereports.htm](http://www.bluejeanscable.com/networkcablereports.htm)



## Cable ID: OCV-5Z-5E

Date / Time: 07/23/2013 09:44:30 AM

Headroom 5.5 dB (NEXT 36-45)

Test Limit: TIA Patch Cord Cat5e 2.0m

Cable Type: Cat 6 UTP

Operator: BJC

Software Version: 2.7400

Limits Version: 1.9300

NVP: 69.0%

## Test Summary: PASS

Model: DTX-1800

Main S/N: 2300619


Remote S/N: 2300620

Main Adapter: DTX-PC5E/MN

Remote Adapter: DTX-PC5E/SR


Wire Map	1	2	3	4	5	6	7	8
<b>PASS</b>								
(T568B)	1	2	3	4	5	6	7	8

Length (ft)	[Pair 12]	5
Prop. Delay (ns)	[Pair 45]	8
Delay Skew (ns)	[Pair 45]	1
Resistance (ohms)	[Pair 36]	0.6



Worst Case Margin Worst Case Value

<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	36-45	36-45		
<b>NEXT (dB)</b>	5.5	5.5		
Freq. (MHz)	99.8	99.8		
Limit (dB)	39.3	39.3		



<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	36	36		
<b>RL (dB)</b>	3.3	7.0		
Freq. (MHz)	25.0	91.0		
Limit (dB)	24.0	18.4		

